Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02** **Date: 04/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/01

Customer ID : C.C Road

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 04/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	C.C Road	M20	28/12/2017	04/01/2018	150.42 X 150.54 X 150.50	22644	8.451	389.5	17.2	17.6
2	C.C Road	M20	28/12/2017	04/01/2018	150.32 X 150.30 X 150.33	22593	8.389	408.9	18.1	
3	C.C Road	M20	28/12/2017	04/01/2018	150.34 X 150.38 X 150.29	22608	8.376	395.6	17.5	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02**

Date: 25/01/2018

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/02

Customer ID : C.C Road

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	C.C Road	M20	28/12/2017	25/01/2018	149.33 X 152.01 X 150.26	22700	8.224	513.0	22.6	22.8
2	C.C Road	M20	28/12/2017	25/01/2018	151.64 X 150.49 X 151.48	22820	8.179	529.4	23.2	
3	C.C Road	M20	28/12/2017	25/01/2018	150.86 X 150.67 X 151.46	22730	8.158	513.7	22.6	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02** **Date: 06/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/07

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 06/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	30/12/2017	06/01/2018	149.48 X 150.73 X 151.74	22531	8.258	387.5	17.2	16.9
2	Drain Concrete	M20	30/12/2017	06/01/2018	151.28 X 149.36 X 151.65	22595	8.233	379.6	16.8	
3	Drain Concrete	M20	30/12/2017	06/01/2018	151.20 X 150.33 X 150.47	22730	8.154	381.9	16.8	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO BANGALORE Sig..... Date.....

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02**

Date: 27/01/2018

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/08

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 27/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	30/12/2017	27/01/2018	150.32 X 150.32 X 150.34	22596	8.435	483.6	21.4	21.3
2	Drain Concrete	M20	30/12/2017	27/01/2018	150.31 X 150.39 X 150.32	22605	8.456	486.0	21.5	
3	Drain Concrete	M20	30/12/2017	27/01/2018	150.33 X 150.32 X 150.34	22598	8.443	476.8	21.1	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02** **Date: 06/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/05

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 06/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	30/12/2017	06/01/2018	151.23 X 150.65 X 150.76	22783	8.264	401.0	17.6	17.6
2	Drain Concrete	M20	30/12/2017	06/01/2018	151.46 X 151.00 X 151.76	22870	8.259	416.2	18.2	
3	Drain Concrete	M20	30/12/2017	06/01/2018	149.86 X 149.63 X 150.64	22424	8.187	379.0	16.9	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02** **Date: 27/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/06

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 27/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	30/12/2017	27/01/2018	151.22 X 150.47 X 150.98	22754	8.147	525.6	23.1	23.7
2	Drain Concrete	M20	30/12/2017	27/01/2018	15.33 X 150.47 X 150.98	2307	8.169	56.5	24.5	
3	Drain Concrete	M20	30/12/2017	27/01/2018	150.55 X 150.98 X 150.37	22730	8.174	531.9	23.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-02-02**

Date: 04/01/2018

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 02-01-18

Sample ID No : 2018-01-02-02/03

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 04/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	28/12/2017	04/01/2018	150.21 X 150.34 X 150.20	22583	8.301	365.8	16.2	16.5
2	Drain Concrete	M20	28/12/2017	04/01/2018	150.20 X 150.30 X 150.36	22575	8.349	379.3	16.8	
3	Drain Concrete	M20	28/12/2017	04/01/2018	150.34 X 150.36 X 150.27	22605	8.326	370.7	16.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-02-02** **Date: 25/01/2018**
Customer	:	Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.
Address	:	Project Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03
Agency	:	Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157
Customer's Reference	:	EE(Project)/YnkZone/WO/88/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	02-01-18
Sample ID No	:	2018-01-02-02/04
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	25/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	28/12/2017	25/01/2018	150.47 X 150.82 X 150.22	22694	8.176	517.9	22.8	22.7
2	Drain Concrete	M20	28/12/2017	25/01/2018	150.72 X 150.38 X 150.83	22665	8.143	496.8	21.9	
3	Drain Concrete	M20	28/12/2017	25/01/2018	150.22 X 150.37 X 150.82	22589	8.192	529.0	23.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-08-02** **Date: 08/01/2018**
Customer	:	Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.
Address	:	Project Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03
Agency	:	Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157
Customer's Reference	:	EE(Project)/YnkZone/WO/88/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	08-01-18
Sample ID No	:	2018-01-08-02/01
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	08/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	01/01/2018	08/01/2018	151.98 X 150.82 X 150.28	22922	8.176	382.8	16.7	16.9
2	Drain Concrete	M20	01/01/2018	08/01/2018	150.76 X 150.88 X 150.67	22747	8.143	391.2	17.2	
3	Drain Concrete	M20	01/01/2018	08/01/2018	150.20 X 150.92 X 150.87	22668	8.192	383.1	16.9	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-08-02** **Date: 29/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 08-01-18

Sample ID No : 2018-01-08-02/02

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 29/01/2018

SL No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	01/01/2018	29/01/2018	150.79 X 150.34 X 150.22	22670	8.112	473.8	20.9	21.3
2	Drain Concrete	M20	01/01/2018	29/01/2018	150.19 X 150.48 X 150.25	22601	8.113	483.7	21.4	
3	Drain Concrete	M20	01/01/2018	29/01/2018	150.32 X 150.98 X 150.21	22695	8.281	492.5	21.7	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF PRECAST COVER SLAB

Lab ID : CP-2017-12-25-03 **Date: 29-12-17**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Improvements to roads and Drains Balance cross roads of Chikkadinne in Attur Ward.No.03

Agency : Sri.B.P.Mahesh, S/o.B.L.Puttanna, No.58, BP Linganna Building, Chandramouleshwarahalli, Hunasamaranahalli, Bangalore-562157

Customer's Reference : EE(Project)/YnkZone/WO/88/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 25-12-17

Sample ID No : 2017-12-25-03/05

Sample Type /Size : Precast Cover Slab

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete

Date of test : 25/12/2017

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	(kg)	(Sq.mm)	(KN)	(N/mm^2)	(N/mm^2)	(N/mm^2)
1	Cover Slab-1	75.51	100.45	1.816	4477	83.9	18.7	17.4	21.8
2	Cover Slab-2	75.49	100.50	1.722	4475	84.3	18.8	17.5	21.9
3	Cover Slab-3	75.52	100.47	1.858	4478	82.5	18.4	17.1	21.4

Note:

The results pertain to the samples received and tested.
All information furnished by the Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |